



12 Dec 2011

Infocomm Development Authority of Singapore
10 Pasir Panjang Road
#10-01 Mapletree Business City
Singapore 117438

Attn: Ms Aileen Chia

Dear Ms Chia,

PUBLIC CONSULTATION ON THE REVIEW OF COPIF

We refer to IDA's consultation paper dated 4 November 2011 on the review of COPIF.

Attached are CityNet's comments on the review for issues relevant to its operations.

Thank you.

Yours faithfully,

Chong Kim Koon
CityNet Infrastructure Management Pte Ltd
(as Trustee-Manager of NetLink Trust)
Tel: 65818759

CityNet Infrastructure Management Pte. Ltd.
(as Trustee-Manager of NetLink Trust)

Reg No. 201117019K
111 Somerset Road, TripleOne Somerset, #02-05, Singapore 238164
Tel : (65) 6594 9828 Fax : (65) 6594 9811 www.citynetlink.com.sg

PUBLIC CONSULTATION ON THE REVIEW OF COPIF

Submission of Comments by CityNet Infrastructure Management

Section 5

- i) IDA proposes : For new Development, the proposed sealing of all underground pipes by developers prior to the handing over of such pipes to telecommunication licensees

CityNet comments: CityNet supports this proposal and further proposes that developer is to use proper duct sealing system such as Multi Cable Transit (MCT) system or equivalent for ease of future re-opening and re-sealing of duct after cable installation work.

- ii) IDA proposes : For new Development, the proposed sealing of underground pipes by telecommunication licensees after cable installation works in building

CityNet comments: CityNet supports this proposal that the re-sealing of used duct is to be carried out by the telecommunication licensee which has carried out the cable installation work.