



CITYNET INFRASTRUCTURE MANAGEMENT PTE LTD
(as Trustee-Manager of NetLink Trust)

1 Serangoon North Avenue 5
#04-02 Singapore 554915
Tel: (65) 6887 9333 Fax: (65) 6887 9334
www.citynetlink.com.sg

12 July 2012

Infocomm Development Authority of Singapore
10 Pasir Panjang Road
#10-01 Mapletree Business City
Singapore 117438

Attn: Ms Aileen Chia
Deputy Director-General
Telecoms & Post

Dear Ms Chia

Public consultation on the Review of the Code of Practice for Info-communication Facilities in Buildings (COPIF)

We refer to IDA's 2nd Public Consultation Document Released on 22 June 2012 in which IDA has published an explanatory memorandum, draft revised COPIF and the associated COPIF Guidelines and also our earlier comments to IDA dated 12 December 2011 concerning the sealing of underground pipes entering the MDF, TER and telecommunication risers.

We are pleased and satisfied with the feedback and consideration taken by IDA to clarify the following points raised:

1. That the sealing of the underground pipes shall be a shared responsibility between the developers/owners and the telecommunication licensees based on clear guidelines within 2 years from the effective date of the revised COPIF.
2. That the sealing system and method shall be the developers', owners' and licensees' own arrangements as long as the chosen system satisfies the requirements stipulated in the COPIF.

Based on the above, CityNet has no other view and comment but wish to express its full appreciation for the added clarity by IDA to the revised COPIF.

Yours truly
CityNet Infrastructure Management Pte Ltd



Thomas Tsang
General Manager